

Part III Form 2
Section 11. ANNUAL REPORT.

Drinking-Water System Number:	220009194
Drinking-Water System Name:	Hamilton Drive Water Supply System
Drinking-Water System Owner:	The Corporation of the Township of Guelph Eramosa
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	January 1, 2005 – December 31, 2005

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px; margin-top: 10px;"> Township Guelph-Eramosa 8348 Wellington Road, 124 PO Box 3000 Rockwood Ontario, N0B 2K0 </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <div style="border: 1px solid black; width: 100px; height: 20px; margin: 5px auto;"></div> </p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <div style="border: 1px solid black; width: 100px; height: 20px; margin: 5px auto;"></div> </p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p>
--	---

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [] No [] Not Applicable [X]

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web**
- Public access/notice via Government Office**
- Public access/notice via a newspaper**
- Public access/notice via Public Request**
- Public access/notice via a Public Library**
- Public access/notice via other method** - notice via Water or Tax Bills

Describe your Drinking-Water System

The Hamilton Drive Water Supply System is located in the Township of Guelph-Eramosa. This water system consists of two municipal groundwater wells, two pumphouses, one standpipe and distribution system.

There is one well and in ground reservoir in each of the pumphouses and the water level in the reservoir starts and stops the well pumps. The raw water from each well is chlorinated to protect against microbial contaminants prior to discharge into the reservoir. The raw water is disinfected with a sodium hypochlorite solution (chlorine).

The treated water is pumped with high-lift pumps at each station through the distribution system which consists of approximately 21 kilometers of watermain. The high lift pumps operate based on the water level in the standpipe. Once the low water level in the standpipe is reached, the pump stations are called upon to operate in sequence and supply the distribution system and any excess water fills the standpipe to the high water level. This system is a demand/storage system; once the standpipe is full, the high lift pumps shut down until the water level drops in the tower and the pumps are required again.

List all water treatment chemicals used over this reporting period

Sodium Hypochlorite (12% solution) - disinfection

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

There were no significant expenses incurred during this reporting period to install, repair or replace required equipment

Drinking-Water Systems Regulation O. Reg. 170/03

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
Aug. 22/05	Total Coliform	1	CFU/ 100ml	Resample	Aug.24/05

Microbiological testing done under the Schedule 10 of Regulation 170/03, during this reporting period.

	# of Samples	E.coli (min – max)	Total Coliform (min – max)	# of HPC Samples	HPC (min – max)	# of Bkgrd Samples	Bkgrd (min - max)
Raw	102	0 - 0	0 - 0	4	0 - 0	2	0 - 0
Treated	102	0 - 0	0 - 0	70	0 - 2	34	0 - 4
Distribution	163	0 - 0	0 - 1	109	0 - 4	52	0 - 20

Operational testing done under Schedule 7 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min – max)
Raw Water		
Turbidity (Huntington)	20	0.07-1.30 NTU
Turbidity (Cross Creek)	21	0.06-0.42 NTU
Treated Water		
Turbidity (Huntington)	8760	.02 – 4.0 NTU ¹
Turbidity (Cross Creek)	8760	.01 – 5.0 NTU ¹
Chlorine Residual (Huntington)	8760	.30 – 5.0 ²
Chlorine Residual (Cross Creek)	8760	.32 – 2.57
Distribution System		
Chlorine Residual	8760	.22 – 2.42
Fluoride (If the DWS provides fluoridation)		
	N/A	N/A

NOTE: For continuous monitors use 8760 as the number of samples.

¹ Turbidity Spikes Mechanically Related

² Chlorine Spikes Mechanically Related

NOTE: Record the unit of measure if it is not milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A				

Drinking-Water Systems Regulation O. Reg. 170/03

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
HUNTINGTON				
Antimony	Aug 19/03	<0.6	ug/l	No
Arsenic	Aug 19/03	<2	ug/l	No
Barium	Aug 19/03	41	ug/l	No
Boron	Aug 19/03	26	ug/l	No
Cadmium	Aug 19/03	<0.1	ug/l	No
Chromium	Aug 19/03	<3	ug/l	No
Lead Distribution	July 07/05	<0.1	ug/l	No
Mercury	Aug 19/03	<0.1	ug/l	No
Selenium	Aug 19/03	<3	ug/l	No
Sodium	Aug 19/03	11.6	mg/l	No
Uranium	Aug 19/03	0.05	ug/l	No
Fluoride	Aug 19/03	0.14	mg/l	No
Nitrite	Jan. 17/05 Apr. 11/05 July 07/05 Oct. 05/05	<0.043 <0.005 <0.005 <0.005	mg/l	No
Nitrate	Jan. 17/05 Apr. 11/05 July 07/05 Oct. 05/05	<0.013 <0.013 0.013 <0.013	mg/l	No

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
CROSS CREEK				
Antimony	Aug 19/03	<0.6	ug/l	No
Arsenic	Aug 19/03	<2	ug/l	No
Barium	Aug 19/03	36	ug/l	No
Boron	Aug 19/03	28	ug/l	No
Cadmium	Aug 19/03	<0.1	ug/l	No
Chromium	Aug 19/03	<3	ug/l	No
Lead Distribution	July 07/05	<0.1	ug/l	No
Mercury	Aug 19/03	<0.1	ug/l	No
Selenium	Aug 19/03	<3	ug/l	No
Sodium	Aug 19/03	7.6	mg/l	No
Uranium	Aug 19/03	<0.05	ug/l	No
Fluoride	Aug 19/03	0.12	mg/l	No
Nitrite	Jan. 17/05 Apr. 11/05 July 07/05 Oct. 05/05	<0.005 <0.005 <0.005 <0.005	mg/l	No

CROSS CREEK (cont'd)				
Nitrate	Jan. 17/05	<0.013	mg/l	No
	Apr. 11/05	<0.013		
	July 07/05	0.013		
	Oct. 05/05	<0.013		

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
HUNTINGTON				
Alachlor	Aug 19/03	<0.11	ug/l	No
Aldicarb	Aug 19/03	<0.30	ug/l	No
Aldrin + Dieldrin	Aug 19/03	<0.067	ug/l	No
Atrazine + N-dealkylated metabolites	Aug 19/03	<0.12	ug/l	No
Azinphos-methyl	Aug 19/03	<0.21	ug/l	No
Bendiocarb	Aug 19/03	<0.13	ug/l	No
Benzene	Aug 19/03	<0.36	ug/l	No
Benzo(a)pyrene	Aug 19/03	<0.004	ug/l	No
Bromoxynil	Aug 19/03	<0.094	ug/l	No
Carbaryl	Aug 19/03	<0.16	ug/l	No
Carbofuran	Aug 19/03	<0.37	ug/l	No
Carbon Tetrachloride	Aug 19/03	<0.34	ug/l	No
Chlordane (Total)	Aug 19/03	<0.11	ug/l	No
Chlorpyrifos	Aug 19/03	<0.18	ug/l	No
Cyanazine	Aug 19/03	<0.18	ug/l	No
Diazinon	Aug 19/03	<0.081	ug/l	No
Dicamba	Aug 19/03	<0.17	ug/l	No
1,2-Dichlorobenzene	Aug 19/03	<0.56	ug/l	No
1,4-Dichlorobenzene	Aug 19/03	<0.25	ug/l	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Aug 19/03	<0.14	ug/l	No
1,2-Dichloroethane	Aug 19/03	<0.32	ug/l	No
1,1-Dichloroethylene (vinylidene chloride)	Aug 19/03	<0.52	ug/l	No
Dichloromethane	Aug 19/03	<1.17	ug/l	No
2-4 Dichlorophenol	Aug 19/03	<0.15	ug/l	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Aug 19/03	<0.11	ug/l	No
Diclofop-methyl	Aug 19/03	<0.13	ug/l	No
Dimethoate	Aug 19/03	<0.12	ug/l	No
Dinoseb	Aug 19/03	<0.084	ug/l	No
Diquat	Aug 19/03	<1	ug/l	No
Diuron	Aug 19/03	<0.087	ug/l	No
Glyphosate	Aug 19/03	<6	ug/l	No
Heptachlor + Heptachlor Epoxide	Aug 19/03	<0.11	ug/l	No

HUNTINGTON (cont'd)				
Lindane (Total)	Aug 19/03	<0.056	ug/l	No
Malathion	Aug 19/03	<0.091	ug/l	No
Methoxychlor	Aug 19/03	<0.14	ug/l	No
Metolachlor	Aug 19/03	<0.092	ug/l	No
Metribuzin	Aug 19/03	<0.12	ug/l	No
Monochlorobenzene	Aug 19/03	<0.46	ug/l	No
Paraquat	Aug 19/03	<1	ug/l	No
Parathion	Aug 19/03	<0.18	ug/l	No
Pentachlorophenol	Aug 19/03	<0.15	ug/l	No
Phorate	Aug 19/03	<0.11	ug/l	No
Picloram	Aug 19/03	<0.20	ug/l	No
Polychlorinated Biphenyls(PCB)	Aug 19/03	<0.04	ug/l	No
Prometryne	Aug 19/03	<0.23	ug/l	No
Simazine	Aug 19/03	<0.15	ug/l	No
THM Distribution Guelph Tower (NOTE: show latest annual average) average – 18.20 ug/l	Jan. 17/05 Apr. 11/05 July 07/05 Oct. 05/05	26.0 20.0 1.8 25.0	ug/l	No
Temephos	Aug 19/03	<0.31	ug/l	No
Terbufos	Aug 19/03	<0.12	ug/l	No
Tetrachloroethylene	Aug 19/03	<0.48	ug/l	No
2,3,4,6-Tetrachlorophenol	Aug 19/03	<0.14	ug/l	No
Triallate	Aug 19/03	<0.10	ug/l	No
Trichloroethylene	Aug 19/03	<0.54	ug/l	No
2,4,6-Trichlorophenol	Aug 19/03	<0.25	ug/l	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Aug 19/03	<0.14	ug/l	No
Trifluralin	Aug 19/03	<0.12	ug/l	No
Vinyl Chloride	Aug 19/03	<0.08	ug/l	No

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
CROSS CREEK				
Alachlor	Aug 19/03	<0.11	ug/l	No
Aldicarb	Aug 19/03	<0.30	ug/l	No
Aldrin + Dieldrin	Aug 19/03	<0.067	ug/l	No
Atrazine + N-dealkylated metabolites	Aug 19/03	<0.12	ug/l	No
Azinphos-methyl	Aug 19/03	<0.21	ug/l	No
Bendiocarb	Aug 19/03	<0.13	ug/l	No
Benzene	Aug 19/03	<0.36	ug/l	No
Benzo(a)pyrene	Aug 19/03	<0.004	ug/l	No
Bromoxynil	Aug 19/03	<0.094	ug/l	No
Carbaryl	Aug 19/03	<0.16	ug/l	No

CROSS CREEK (cont'd)				
Carbofuran	Aug 19/03	<0.37	ug/l	No
Carbon Tetrachloride	Aug 19/03	<0.34	ug/l	No
Chlordane (Total)	Aug 19/03	<0.11	ug/l	No
Chlorpyrifos	Aug 19/03	<0.18	ug/l	No
Cyanazine	Aug 19/03	<0.18	ug/l	No
Diazinon	Aug 19/03	<0.081	ug/l	No
Dicamba	Aug 19/03	<0.17	ug/l	No
1,2-Dichlorobenzene	Aug 19/03	<0.56	ug/l	No
1,4-Dichlorobenzene	Aug 19/03	<0.24	ug/l	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Aug 19/03	<0.14	ug/l	No
1,2-Dichloroethane	Aug 19/03	<0.32	ug/l	No
1,1-Dichloroethylene (vinylidene chloride)	Aug 19/03	<0.52	ug/l	No
Dichloromethane	Aug 19/03	<1.17	ug/l	No
2-4 Dichlorophenol	Aug 19/03	<0.15	ug/l	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Aug 19/03	<0.11	ug/l	No
Diclofop-methyl	Aug 19/03	<0.13	ug/l	No
Dimethoate	Aug 19/03	<0.12	ug/l	No
Dinoseb	Aug 19/03	<0.084	ug/l	No
Diquat	Aug 19/03	<1	ug/l	No
Diuron	Aug 19/03	<0.087	ug/l	No
Glyphosate	Aug 19/03	<6	ug/l	No
Heptachlor + Heptachlor Epoxide	Aug 19/03	<0.11	ug/l	No
Lindane (Total)	Aug 19/03	<0.056	ug/l	No
Malathion	Aug 19/03	<0.091	ug/l	No
Methoxychlor	Aug 19/03	<0.14	ug/l	No
Metolachlor	Aug 19/03	<0.092	ug/l	No
Metribuzin	Aug 19/03	<0.12	ug/l	No
Monochlorobenzene	Aug 19/03	<0.46	ug/l	No
Paraquat	Aug 19/03	<1	ug/l	No
Parathion	Aug 19/03	<0.18	ug/l	No
Pentachlorophenol	Aug 19/03	<0.15	ug/l	No
Phorate	Aug 19/03	<0.11	ug/l	No
Picloram	Aug 19/03	<0.20	ug/l	No
Polychlorinated Biphenyls(PCB)	Aug 19/03	<0.04	ug/l	No
Prometryne	Aug 19/03	<0.23	ug/l	No
Simazine	Aug 19/03	<0.15	ug/l	No
THM Distribution Guelph Tower	Jan. 17/05	26.0	ug/l	No
	Apr. 11/05	20.0		
	July 07/05	1.8		
	Oct. 05/05	25.0		
(NOTE: show latest annual average) average – 18.20 ug/l				
Temephos	Aug 19/03	<0.31	ug/l	No
Terbufos	Aug 19/03	<0.12	ug/l	No
Tetrachloroethylene	Aug 19/03	<0.48	ug/l	No

CROSS CREEK (cont'd)				
2,3,4,6-Tetrachlorophenol	Aug 19/03	<0.14	ug/l	No
Triallate	Aug 19/03	<0.10	ug/l	No
Trichloroethylene	Aug 19/03	<0.54	ug/l	No
2,4,6-Trichlorophenol	Aug 19/03	<0.25	ug/l	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Aug 19/03	<0.14	ug/l	No
Trifluralin	Aug 19/03	<0.12	ug/l	No
Vinyl Chloride	Aug 19/03	<0.08	ug/l	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
During this reporting period, there no inorganic or organic parameters that exceeded half the standard prescribed in Schedule 2 of the Ontario Drinking Water Standards.			

(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)